

**Tentative Interim Amendment 2002-2
to the
National Electrical Safety Code
ANSI C2-2002**

23 April 2001

In accordance with Section 13 of its Procedures, the National Electrical Safety Code Committee has issued the following Tentative Interim Amendment (TIA) to ANSI C2, National Electrical Safety Code, 2002 Edition. The TIA was issued by the Secretariat on 23 April 2001, as a result of a proposal submitted by a member of the NESC Main Committee.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedure. It is interim because it is effective only between editions of the code. A TIA automatically becomes a Proposal of the proponent for the next edition of the code; as such, it is then subject to all the procedures of the standards-making process.

Table 232-2 m and ft are revised as follows:

Replace footnote 1 in row 1b, column 2 with unused footnote 6 in both the meter and feet Tables 232-2 thusly:

~~⁶This footnote not used in this edition. This clearance may be reduced to the following values for driveways, parking lots, and alleys not subject to truck traffic:~~

	<u>meters</u>	<u>feet</u>
(a) <u>Insulated live parts limited to 300 V to ground</u>	<u>3.6</u>	<u>12</u>
(b) <u>Insulated live parts limited to 150 V to ground</u>	<u>3.0</u>	<u>10</u>

Also replace footnote 1(b) in row 1d, column 2 with footnote 1 and revise footnote 1 thusly:

~~¹This clearance may be reduced to the following values:~~

	<u>meters</u>	<u>feet</u>
(a) <u>Insulated live parts limited to 300 V to ground</u>	<u>3.6</u>	<u>12</u>
(b) <u>Insulated live parts limited to 150 V to ground</u>	<u>3.0</u>	<u>10</u>

~~¹For insulated live parts limited to 150 V to ground, this value may be reduced to 3.0 m (10 ft).~~

Since the footnote only references 1(b) making this revision eliminates the need for the present footnote 1(a) and 1(b).